

Note:

The temporary service must be within 5 feet of the utility's handhole, secondary stubout or transformer. Location of temporary services beyond 5' must be approved by the utility.


Items owned and installed by the member:

1. 6"x 6"x 8' minimum continuous single structure
2. Meter socket and distribution panel (100-200amp, 120 /240 volt); GFCI receptacle in weatherproof box
3. Ground wire in accordance with NEC
4. Ground rods in accordance with NEC
5. Service entrance conductors 10' Flexible Conduit, 12' wire

Items owned and installed by the utility:

6. Transformer, handhole or stubout
7. Meter

ITEM	MATERIAL	ITEM	MATERIAL

ENGINEER:	NEW CONSTRUCTION SPECIFICATIONS TEMPORARY UNDERGROUND SERVICE	 C&L Electric Cooperative Corporation
-----------	---	---