



C&L Electric
Cooperative Corporation

UNDERGROUND CHECKLIST

Member: _____

Address: _____

Phone Number: _____

Installer/Contractor: _____

Checklist must be completed and returned to C&L. All work and materials must meet the current applicable codes and requirements.

Trench and electric conduit minimum 30" below grade?

Is string pulled in electric conduit?

Is warning tape in place?

Is Trench backfilled?

Is meter base and electric conduit installed and secured?

Are ground rods installed?

Member Signature: _____

Date: _____